

<u>MEETING</u> HENDON AREA PLANNING COMMITTEE
<u>DATE AND TIME</u> THURSDAY 10TH MARCH, 2016 AT 7.00 PM
<u>VENUE</u> HENDON TOWN HALL, THE BURROUGHS, LONDON NW4 4AX

Dear Councillors,

Please find enclosed additional papers relating to the following item for the above mentioned meeting which were not available at the time of collation of the agenda.

Item No	Title of Report	Pages
6.1	ADDENDUM TO ITEM 6 89-91 EDGWAREBURY LANE	1 - 2

Sheri Odoffin sheri.odoffin@barnet.gov.uk 0208 359 3104

This page is intentionally left blank

HENDON AREA PLANNING COMMITTEE

10 MARCH 2016

AGENDA ITEM 6a

ADDENDUM to Item 6 89-91 Edgwarebury Lane

Pages 5-18

Ref: 15/03004/FUL

89-91 Edgwarebury Lane

Condition 1 (approved plans) amended as follows:

- Replace Drawing A.01 Rev 01 with Drawing A.01 Rev 02 (The change in the content of the drawing relates to the front forecourt area)
- Replace A.03 Rev 2 with A.03 Rev 1 (to amend a typo).

The following additional conditions to be added:

Water Consumption

Prior to the first occupation of the new dwellinghouses (Use Class C3) hereby approved they shall all have been constructed to have 100% of the water supplied to them by the mains water infrastructure provided through a water meter or water meters and each new dwelling shall be constructed to include water saving and efficiency measures that comply with Regulation 36(2)(b) of Part G 2 of the Building Regulations to ensure that a maximum of 105 litres of water is consumed per person per day with a fittings based approach should be used to determine the water consumption of the proposed development. The development shall be maintained as such in perpetuity thereafter.

Reason: To encourage the efficient use of water in accordance with policy CS13 of the Barnet Core Strategy (2012) and policy 5.15 of the London Plan (2015).

Accessible and adaptable dwellings

Notwithstanding the details shown in the drawings submitted and otherwise hereby approved, prior to the first occupation of the new dwellinghouses (Use Class C3) permitted under this consent they shall all have been constructed to meet and achieve all the relevant criteria of Part M4(2) of Schedule 1 to the Building Regulations 2010 (or the equivalent standard in such measure of accessibility and adaptability for house design which may replace that scheme in future). The development shall be maintained as such in perpetuity thereafter.

Reason: To ensure the development meets the needs of its future occupiers and to comply with the requirements of policies 3.8, 7.2 and 7.6 of the London Plan (2015) and policies DM02 and DM03 of the Barnet Development Management Policies document (2012)."

Reducing carbon dioxide emissions:

Prior to the first occupation of the development hereby approved it shall be constructed incorporating carbon dioxide emission reduction measures which achieve an improvement of not less than 10% in carbon dioxide emissions when compared to a building constructed to comply with the minimum Target Emission Rate requirements of the 2013 Building Regulations. The development shall be maintained as such in perpetuity thereafter.

Reason: To ensure that the development is sustainable and minimises carbon dioxide emissions and to comply with the requirements of policies DM01 and DM02 of the Barnet

Development Management Polices document (2012) and policies 5.2 and 5.3 of the London Plan (2015).

Page
Ref: 15/07342/HSE
19 Victoria Road

Condition 1 (approved plans) amended to include Front Elevation (Proposed). The change in the content of the drawing relates to the retention of front window above proposed front porch.

Pages 19-28
Ref: 16/00049/FUL
28 Heriot Road

The following additional conditions to be added:

Water Consumption

Prior to the first occupation of the new dwellinghouses (Use Class C3) hereby approved they shall all have been constructed to have 100% of the water supplied to them by the mains water infrastructure provided through a water meter or water meters and each new dwelling shall be constructed to include water saving and efficiency measures that comply with Regulation 36(2)(b) of Part G 2 of the Building Regulations to ensure that a maximum of 105 litres of water is consumed per person per day with a fittings based approach should be used to determine the water consumption of the proposed development. The development shall be maintained as such in perpetuity thereafter.

Reason: To encourage the efficient use of water in accordance with policy CS13 of the Barnet Core Strategy (2012) and policy 5.15 of the London Plan (2015).

Reducing carbon dioxide emissions:

Prior to the first occupation of the development hereby approved it shall be constructed incorporating carbon dioxide emission reduction measures which achieve an improvement of not less than 6% in carbon dioxide emissions when compared to a building constructed to comply with the minimum Target Emission Rate requirements of the 2013 Building Regulations. The development shall be maintained as such in perpetuity thereafter.

Reason: To ensure that the development is sustainable and minimises carbon dioxide emissions and to comply with the requirements of policies DM01 and DM02 of the Barnet Development Management Polices document (2012) and policies 5.2 and 5.3 of the London Plan (2015).