

Pattenden, Daniel

From: Pattenden, Daniel
Sent: 22 January 2015 11:02
To: Pattenden, Daniel
Subject: FW: Funky Brownz

From: heena.patel@london-fire.gov.uk [mailto:heena.patel@london-fire.gov.uk]
Sent: 22 January 2015 10:25
To: Mead, Janet
Cc: Blencowe, Elaine
Subject: Funky Brownz

Hi Janet,

Regarding Funky Brownz, fire safety inspection was carried out on the 6th January 2015 and outcome resulting in an Enforcement Notice being issued to the Responsible Person.

Here are brief outline on what we will be enforcing on:-

First floor used as bedsits for 2 members of staff and 4 paying tenants. All bedroom doors require strips and seals and some of the doors are made up to bridge excessive gaps and not closing fully therefore compromising the means of escape route. Gas boiler and electrical consumer unit in means of escape route not in fire protected material.

Inadequate fire detection provided – fire door with door holding device from bar to basement kitchen not fully shutting and detection required to release mechanism.

Nightclub area has insufficient illuminate exit signage. Exit from mezzanine to final exit is in access of 3m and uneven surface as a trip hazard.

External escape route has uneven surface and large quantity of dog faeces and roaming guard dogs.

Management issues – No emergency plan for staff to follow, no evidence of staff training, no evidence of fire safety systems being adequately maintained. Electrical wiring and sockets in poor state near bar area, and staff not aware of where appliances that are being used as plugged into.

Last risk assessment was carried out in 2013 with action provided to be dealt with but have still not been carried out to date.

Hope this is helpful, if you require any further details please contact me. The completed Enforcement Notice will be issued as soon as possible, and a copy will be sent out to Environmental Health Team and Licensing Team.

Thanks

Heena Patel
Fire Safety Inspecting Officer
Barnet, Enfield & Haringey Team
London Fire Brigade
Fire Safety Regulations : NW Area 1
169 Union Street
London
SE1 0LL
e-mail:- heena.patel@london-fire.gov.uk
Office:- 0208 555 1200 ext. 53282
Mobile:- 07917072504

Visit our website at www.london-fire.gov.uk

(This e-mail is confidential to the addressee(s). If you do not believe that you are the intended addressee, do not use, pass or copy it in any way. If you have received it in error, please delete immediately & telephone the above number).

Email disclaimer

The information in this email may contain confidential or privileged materials.
Please read the full email disclaimer notice at london-fire.gov.uk/EmailDisclaimer

For fire safety advice please go to london-fire.gov.uk/YourSafety