

**Location**                                **114 Regents Park Road London N3 3JG**

**Reference:**                                **15/01021/FUL**                                Received: 18th February 2015  
Accepted: 18th February 2015

Ward:                                         Finchley Church End                                Expiry 15th April 2015

Applicant:                                 Mr Lior Asif

Proposal:                                    Demolition of existing building and erection of new 4 storey building to create 8no. self-contained flats including lower ground floor level with parking area for 12no. parking spaces and storage; hard/soft landscaping and refuse/recycling facilities

**Recommendation:** Approve subject to conditions

- 1     The development hereby permitted shall be carried out in accordance with the following approved plans: A1.03\_EX Reva; A2.01\_EX Reva; A2.02\_EX Reva; A2.03\_EX Reva; A1.01\_PR RevC; A1.02\_PR RevC; A1.03\_PR RevC; A1.04\_PR RevC; A1.05\_PR RevC; A1.06\_PR RevC; A2.01\_PR RevC; A2.02\_PR RevC; A2.03\_PR RevC; A2.04\_PR RevC; A3.01\_PR RevC; A3.02\_PR RevC; A3.03\_PR RevC; A3.04\_PR RevC; A1.09; A5.01 RevC.

Reason: For the avoidance of doubt and in the interests of proper planning and so as to ensure that the development is carried out fully in accordance with the plans as assessed in accordance with Policies CS NPPF and CS1 of the Local Plan Core Strategy DPD (adopted September 2012) and Policy DM01 of the Local Plan Development Management Policies DPD (adopted September 2012).

- 2     This development must be begun within three years from the date of this permission.

Reason: To comply with Section 51 of the Planning and Compulsory Purchase Act 2004.

- 3     a) No development other than demolition works shall take place until details of the materials to be used for the external surfaces of the building(s), details of the materials to be used for the windows and doors and hard surfaced areas hereby approved have been submitted to and approved in writing by the Local Planning Authority.

b) The development shall thereafter be implemented in accordance with the materials as approved under this condition.

Reason: To safeguard the character and visual amenities of the site and wider area and to ensure that the building is constructed in accordance with Policies CS NPPF and CS1 of the Local Plan Core Strategy (adopted September 2012), Policy DM01 of the Development Management Policies DPD (adopted September 2012) and Policies 1.1, 7.4, 7.5 and 7.6 of the London Plan 2011.

- 4 a) No development shall take place until details of the levels of the building(s), road(s) and footpath(s) in relation to the adjoining land and highway(s) and any other changes proposed in the levels of the site have been submitted to and approved in writing by the Local Planning Authority.
- b) The development shall thereafter be implemented in accordance with the details as approved under this condition and retained as such thereafter.

Reason: To ensure that the development is carried out at suitable levels in relation to the highway and adjoining land having regard to drainage, gradient of access, the safety and amenities of users of the site, the amenities of the area and the health of any trees or vegetation in accordance with policies CS NPPF, CS1, CS5 and CS7 of the Local Plan Core Strategy (adopted September 2012), Policies DM01, DM04 and DM17 of the Development Management Policies DPD (adopted September 2012), and Policies 7.4, 7.5, 7.6 and 7.21 of the London Plan 2011.

- 5 The development shall be implemented in full accordance with the details of the refuse and recycling as shown on drawing A1.02\_PR RevC prior to the first occupation and retained as such thereafter.

Reason: To ensure a satisfactory appearance for the development and satisfactory accessibility; and to protect the amenities of the area in accordance with policies DM01 of the Adopted Barnet Development Management Policies DPD (2012) and CS14 of the Adopted Barnet Core Strategy DPD (2012).

- 6 No construction work resulting from the planning permission shall be carried out on the premises at any time on Sundays, Bank or Public Holidays, before 8.00 am or after 1.00 pm on Saturdays, or before 8.00 am or after 6.00pm pm on other days.

Reason: To ensure that the proposed development does not prejudice the amenities of occupiers of adjoining residential properties in accordance with policy DM04 of the Development Management Policies DPD (adopted September 2012).

- 7 The property shall be used as self-contained units as shown in the hereby approved drawings under Class C3(a) and no other purpose (including any other purpose in Class C3 or C4 of the Schedule to the Town and Country Planning (Use Classes) Order 1987, or in any provision equivalent to that Class in any statutory instrument revoking and re-enacting that Order, with or without modification).

Reason: To enable the Local Planning Authority to exercise control of the type of use within the category in order to safeguard the amenities of the area.

- 8 Before the building hereby permitted is first occupied the proposed window(s) in the side elevation facing 112 Regents Park Road shall be glazed with obscure glass only and shall be permanently retained as such thereafter and shall be permanently fixed shut with only a fanlight opening.

Reason: To safeguard the privacy and amenities of occupiers of adjoining residential properties in accordance with Policy DM01 of the Development Management Policies DPD (adopted September 2012) and the Residential Design Guidance SPD (adopted April 2013).

- 9 a) No development shall take place until a scheme of proposed noise mitigation measures against externally generated traffic noise has been submitted to and approved in writing by the Local Planning Authority.
- b) The mitigation measures as approved under this condition shall be implemented in their entirety prior to the commencement of the use or the first occupation of the development and retained as such thereafter.

Reason: To ensure the amenities of occupiers are not prejudiced by traffic noise in the immediate surroundings, in accordance with Policies DM04 of the Development Management Policies DPD (adopted September 2012), the Sustainable Design and Construction SPD (adopted April 2013), and 7.15 of The London Plan 2011.

- 10 a) No development other than demolition works shall take place until details of all extraction and ventilation equipment to be installed as part of the development have been submitted to and approved in writing by the Local Planning Authority. The report shall include all calculations and baseline data, and be set out so that the Local Planning Authority can fully audit the report and critically analyse the content and recommendations.
- b) The development shall be implemented in accordance with details approved under this condition before first occupation or the use is commenced and retained as such thereafter.

Reason: To ensure a satisfactory appearance for the development and satisfactory accessibility; and to protect the amenities of the area in accordance with Policy DM04 of the Development Management Policies DPD (adopted September 2012) and Policy CS13 of the Local Plan Core Strategy (adopted September 2012).

- 11 The level of noise emitted from the site plant hereby approved shall be at least 5dB(A) below the background level, as measured from any point 1 metre outside the window of any room of a neighbouring residential property.

If the noise emitted has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or distinct impulse (bangs, clicks, clatters, thumps), then it shall be at least 10dB(A) below the background level, as measured from any point 1 metre outside the window of any room of a neighbouring residential property.

Reason: To ensure that the proposed development does not prejudice the amenities of occupiers of neighbouring properties in accordance with Policies DM04 of the Development Management Policies DPD (adopted September 2012) and 7.15 of the London Plan 2011.

- 12 a) No development other than demolition works shall commence on site in connection with the development hereby approved until a report has been carried out by a competent acoustic consultant that assesses the likely noise impacts from the development of the ventilation/extraction plant, and mitigation measures for the

development to reduce these noise impacts to acceptable levels, and has been submitted to and approved in writing by the Local Planning Authority.

The report shall include all calculations and baseline data, and be set out so that the Local Planning Authority can fully audit the report and critically analyse the content and recommendations.

b) The measures approved under this condition shall be implemented in their entirety prior to the commencement of the use/first occupation of the development and retained as such thereafter.

Reason: To ensure that the proposed development does not prejudice the amenities of occupiers of neighbouring properties in accordance with Policy DM04 of the Development Management Policies DPD (adopted September 2012), the Sustainable Design and Construction SPD (adopted April 2013) and Policy 7.15 of the London Plan 2011.

- 13 a) No development shall take place until details of mitigation measures to show how the development will be constructed/adapted so as to provide sufficient air borne and structure borne sound insulation against internally/externally generated noise and vibration has been submitted to and approved in writing by the Local Planning Authority.

This sound insulation shall ensure that the levels of noise generated from the \*\*\*\* as measured within habitable rooms of the development shall be no higher than 30dB(A) from 7am to 11pm and 30dB(A) in bedrooms from 11pm to 7am.

The report shall include all calculations and baseline data, and be set out so that the Local Planning Authority can fully audit the report and critically analyse the content and recommendations.

b) The mitigation measures as approved under this condition shall be implemented in their entirety prior to the commencement of the use or first occupation of the development and retained as such thereafter.

Reason: To ensure that the proposed development does not prejudice the amenities of occupiers of the residential properties in accordance with Policies DM04 of the Development Management Policies DPD (adopted September 2012), the Sustainable Design and Construction SPD, and 7.15 of the London Plan 2011.

- 14 Part 1

Before development commences other than for investigative work:

A desktop study (Preliminary Risk Assessment) shall be carried out which shall include the identification of previous uses, potential contaminants that might be expected, given those uses, and other relevant information. Using this information, a diagrammatical representation (Conceptual Model) for the site of all potential contaminant sources, pathways and receptors shall be produced. The desktop study (Preliminary Risk Assessment) and Conceptual Model shall be submitted to the Local Planning Authority. If the desktop study and Conceptual Model indicate no risk of harm, development shall not commence until approved in writing by the Local Planning Authority.

If the desktop study and Conceptual Model indicate any risk of harm, a site investigation shall be designed for the site using information obtained from the desktop study and Conceptual Model. This shall be submitted to, and approved in writing by, the Local Planning Authority prior to that investigation being carried out on site. The investigation must be comprehensive enough to enable:

- a risk assessment to be undertaken,
- refinement of the Conceptual Model, and
- the development of a Method Statement detailing the remediation requirements.

The risk assessment and refined Conceptual Model shall be submitted, along with the site investigation report, to the Local Planning Authority.

If the risk assessment and refined Conceptual Model indicate any risk of harm, a Method Statement detailing the remediation requirements, using the information obtained from the site investigation, and also detailing any post remedial monitoring shall be submitted to, and approved in writing by, the Local Planning Authority prior to that remediation being carried out on site.

## Part 2

Where remediation of contamination on the site is required completion of the remediation detailed in the method statement shall be carried out and a report that provides verification that the required works have been carried out, shall be submitted to, and approved in writing by the Local Planning Authority before the development is occupied.

Reason: To ensure the development can be implemented and occupied with adequate regard for environmental and public safety in accordance with Policy CS NPPF of the Local Plan Core Strategy DPD (adopted September 2012), DM04 of the Development Management Policies DPD (adopted September 2012), the Sustainable Design and Construction SPD (adopted April 2013) and 5.21 of the London Plan 2011.

- 15 a) Notwithstanding the details shown on the plans submitted and otherwise hereby approved, the development hereby approved shall not be first occupied or brought into use until details of all acoustic walls, fencing and other acoustic barriers to be erected on the site have been submitted to the Local Planning Authority and approved in writing.

b) The details approved by this condition shall be implemented in their entirety prior to the commencement of the use or first occupation of the development and retained as such thereafter.

Reason: To ensure that the proposed development does not prejudice the enjoyment of the occupiers of their homes in accordance with Policy DM04 of the Development Management Policies DPD (adopted September 2012) and Policy 7.15 of the London Plan 2011.

- 16 Prior to the first occupation of the units, copies of Pre-completion Sound Insulation Test Certificates shall be submitted to the Local Planning Authority, confirming compliance with Requirement E of the Building Regulations 2010 (or any subsequent amendment in force at the time of implementation of the permission).

Reason: To protect the amenities of future and neighbouring residential occupiers in accordance with Policies DM02 and DM04 of the Development Management Policies DPD (adopted September 2012) and the Sustainable Design and Construction SPD (adopted April 2013).

- 17 Before the development hereby permitted is occupied, car parking should be provided in accordance with submitted drawings A1 01 PR RevC and spaces shall not be used for any purpose other than parking of vehicles in connection with the approved development. The parking layout should include one space suitable for disable use.

Reason: To ensure that adequate and satisfactory provision is made for the parking of vehicles in the interests of pedestrian and highway safety and the free flow of traffic in accordance with policies London Borough of Barnet's Local Plan Policy CS9 of Core Strategy (Adopted) September 2012 and Policy DM17 of Development Management Policies (Adopted) September 2012.

- 18 The applicant should submit a scheme showing details of the proposed access layout for approval, including layout and ramp gradient details for access to car parks car parking area. The detailed layout must include a waiting bay within the site on both approaches to the ramp.

Reason: To ensure the safe form of access to the development to conform to London Borough of Barnet's Local Plan Policy CS9 of Core Strategy (Adopted) September 2012 and Policy DM17 of Development Management Policies (Adopted) September 2012.

- 19 A warning system giving preference to vehicles entering the site should be provided to manage the one way operation of the ramp.

Reason: To ensure the safe form of access to the development and to conform to London Borough of Barnet's Local Plan Policy CS9 of Core Strategy (Adopted) September 2012 and Policy DM17 of Development Management Policies (Adopted) September 2012.

- 20 a) No development or site works shall take place on site until a 'Demolition & Construction Method Statement' has been submitted to and approved in writing by, the Local Planning Authority.

The Statement shall provide for: access to the site; the parking of vehicles for site operatives and visitors; hours of construction, including deliveries, loading and unloading of plant and materials; the storage of plant and materials used in the construction of the development; the erection of any means of temporary enclosure or security hoarding and measures to prevent mud and debris being carried on to the public highway and ways to minimise pollution.

b) The development shall thereafter be implemented in accordance with the measures detailed within the statement.

Reason: In the interests of highway safety and good air quality in accordance with Policies DM04 and DM17 of the Development Management Policies DPD (adopted

September 2012), the Sustainable Design and Construction SPD (adopted April 2013) and Policy 5.21 of the London Plan (2011).

- 21 The approved development shall make provision for cycle parking and cycle storage facilities in accordance with a scheme that shall be submitted to and approved by the Local Planning Authority. Such spaces shall be permanently retained thereafter.

Reason: In the interests of promoting cycling as a mode of transport in accordance with London Borough of Barnet's Local Plan Policy CS9 of Core Strategy (Adopted) September 2012 and Policy DM17 of Development Management Policies (Adopted) September 2012.

- 22 Before the development hereby permitted commences details of the Electric Vehicle Charging Points with 20% active and 20% passive shall be submitted to and agreed in writing by the Local Planning Authority.

Reason: To ensure that the Electric Vehicular Charging provision is in accordance with the London Plan requirements.

- 23 Prior to the occupation of each phases hereby approved, a Car Parking Management Plan detailing the following shall be submitted to and approved in writing by the Local Planning Authority:

- i. location and layout of car parking spaces,
- ii. The allocation of car parking spaces;
- iii. On site parking controls
- iv. The enforcement of unauthorised parking; and
- v. disabled parking spaces
- vi. Electrical Vehicle Charging Points.

The Car Park Management Plan should include details of the proposed monitoring of EVCP and disabled parking spaces, to inform when additional spaces are required to be brought into operation.

Reason: To ensure that parking is provided and managed in line with the council's standards in the interests of highway and pedestrian safety in accordance with London Borough of Barnet's Local Plan Policy CS9 of Core Strategy (Adopted) September 2012 and Policy DM17 of Development Management Policies (Adopted) September 2012.

- 24 Prior to the first occupation of the new dwellinghouses (Use Class C3) hereby approved they shall all have been constructed to meet and achieve all the relevant criteria of 'The Lifetime Homes' standard (or the equivalent standard in such measure of accessibility and adaptability for house design which may replace that scheme in future). The development shall be maintained as such in perpetuity thereafter.

Reason:

To ensure the development meets the needs of its future occupiers and to comply with the requirements of policies 3.8 and 7.2 of the London Plan (2015) and policy DM02 of the Barnet Development Management Polices document (2012).

- 25 Prior to the first occupation of the development hereby approved it shall be constructed incorporating carbon dioxide emission reduction measures which achieve an improvement of not less than 40% in carbon dioxide emissions when compared to a building constructed to comply with the minimum Target Emission Rate requirements of the 2010 Building Regulations. The development shall be maintained as such in perpetuity thereafter.

Reason:

To ensure that the development is sustainable and minimises carbon dioxide emissions and to comply with the requirements of policies DM01 and DM02 of the Barnet Development Management Policies document (2012) and policies 5.2 and 5.3 of the London Plan (2015).

- 26 Prior to the first occupation of the new dwellinghouses (Use Class C3) hereby approved they shall all have been constructed to have 100% of the water supplied to them by the mains water infrastructure provided through a water meter or water meters and each new dwelling shall be constructed to include water saving and efficiency measures so that mains water consumption would meet a standard of 105 litres per head per day or less. The development shall be maintained as such in perpetuity thereafter.

Reason:

To encourage the efficient use of water in accordance with policy CS13 of the Barnet Core Strategy (2012) and policy 5.15 of the London Plan (2015).

- 27 a) Before development commences, a scheme of proposed air pollution mitigation measures shall be submitted to and approved in writing by the Local Planning Authority.
- b) The approved mitigation scheme shall be implemented in its entirety in accordance with details approved under this condition before any of the development is first occupied or the use commences and retained as such thereafter.

Reason: To ensure that the amenities of occupiers are protected from the poor air quality in the vicinity in accordance with Policy DM04 of the Development Management Policies DPD (adopted September 2012), the Sustainable Design and Construction SPD, and Policy 5.3 of the London Plan 2011.

- 28 a) No development other than demolition works shall take place until details of the proposed green roof, landscaping have been submitted to and approved in writing by the Local Planning Authority.
- b) The green roof shall be implemented in accordance with the details approved this condition prior to the commencement of the use or first occupation of the development and retained as such thereafter. Should part of the approved green roof be removed, die, become severely damaged or diseased within five years of the completion of development, it shall be replaced in accordance with the details approved by this condition.

Reason: To ensure that the proposed development does not prejudice the enjoyment of the occupiers of their homes in accordance with Policies DM04 of the



Development Management Policies DPD (adopted September 2012) and 7.15 of the London Plan 2011.

29 a) No development shall take place until a scheme of hard and soft landscaping to the front forecourt area, including details of existing trees to be retained and size, species, planting heights, densities and positions of any soft landscaping, has been submitted to and agreed in writing by the Local Planning Authority.

b) All work comprised in the approved scheme of landscaping shall be carried out before the end of the first planting and seeding season following occupation of any part of the buildings or completion of the development, whichever is sooner, or commencement of the use.

c) Any existing tree shown to be retained or trees or shrubs to be planted as part of the approved landscaping scheme which are removed, die, become severely damaged or diseased within five years of the completion of development shall be replaced with trees or shrubs of appropriate size and species in the next planting season.

Reason: To ensure a satisfactory appearance to the development in accordance with Policies CS5 and CS7 of the Local Plan Core Strategy DPD (adopted September 2012), Policy DM01 of the Development Management Policies DPD (adopted September 2012), the Sustainable Design and Construction SPD (adopted April 2013) and 7.21 of the London Plan 2011.

30 a) The site shall not be brought into use or first occupied until details of the means of enclosure, including boundary treatments, have been submitted to and approved in writing by the Local Planning Authority.

b) The development shall be implemented in accordance with the details approved as part of this condition before first occupation or the use is commenced and retained as such thereafter.

Reason: To ensure that the proposed development does not prejudice the appearance of the locality and/or the amenities of occupiers of adjoining residential properties and to confine access to the permitted points in the interest of the flow of traffic and conditions of general safety on the adjoining highway in accordance with Policies DM01, DM03, DM17 of the Development Management Policies DPD (adopted September 2012), and Policies CS NPPF and CS1 of the Local Plan Core Strategy (adopted September 2012).

31 a) Before the development hereby permitted is first occupied, details of privacy screens to be installed shall be submitted to and approved in writing by the Local Planning Authority.

b) The screens shall be installed in accordance with the details approved under this condition before first occupation or the use is commenced and retained as such thereafter.

Reason: To ensure that the development does not prejudice the amenity of future occupiers or the character of the area in accordance with policies DM01 and DM02 of the Development Management Policies DPD (adopted September 2012), the

Residential Design Guidance SPD (adopted April 2013) and the Sustainable Design and Construction SPD (adopted April 2013).

32 a) Before the development hereby permitted is first occupied, details of the sub-division of the amenity area(s) shall be submitted to and approved in writing by the Local Planning Authority.

b) The development shall be implemented in accordance with the details approved under this condition before first occupation or the use is commenced and retained as such thereafter.

Reason: To ensure that the development does not prejudice the amenity of future occupiers or the character of the area in accordance with policies DM01 and DM02 of the Development Management Policies DPD (adopted September 2012) and the Sustainable Design and Construction SPD (adopted April 2013).

#### **Informative(s):**

- 1 In accordance with paragraphs 186 and 187 of the NPPF, the Local Planning Authority (LPA) takes a positive and proactive approach to development proposals, focused on solutions. The LPA has produced planning policies and written guidance to assist applicants when submitting applications. These are all available on the Council's website. A pre-application advice service is also offered and the Applicant engaged with this prior to the submissions of this application. The LPA has negotiated with the applicant/agent where necessary during the application process to ensure that the proposed development is in accordance with the Development Plan.
- 2 The Community Infrastructure Levy (CIL) applies to all 'chargeable development'. This is defined as development of one or more additional units, and / or an increase to existing floor space of more than 100 sq m. Details of how the calculations work are provided in guidance documents on the Planning Portal at [www.planningportal.gov.uk/cil](http://www.planningportal.gov.uk/cil).

The Mayor of London adopted a CIL charge on 1st April 2012 setting a rate of £35 per sq m on all forms of development in Barnet except for education and health developments which are exempt from this charge. Your planning application has been assessed at this time as liable for a £168,075.00 payment under Mayoral CIL.

The London Borough of Barnet adopted a CIL charge on 1st May 2013 setting a rate of £135 per sq m on residential and retail development in its area of authority. All other uses and ancillary car parking are exempt from this charge. Your planning application has therefore been assessed at this time as liable for a £102,060.00 payment under Barnet CIL.

Please note that Indexation will be added in line with Regulation 40 of Community Infrastructure Levy.

Liability for CIL will be recorded to the register of Local Land Charges as a legal charge upon your site payable should you commence development. Receipts of the Mayoral CIL charge are collected by the London Borough of Barnet on behalf of the Mayor of London; receipts are passed across to Transport for London to support Crossrail, London's highest infrastructure priority.

You will be sent a 'Liability Notice' that provides full details of the charge and to whom it has been apportioned for payment. If you wish to identify named parties other than the applicant for this permission as the liable party for paying this levy, please submit to the Council an 'Assumption of Liability' notice, which is also available from the Planning Portal website.

The CIL becomes payable upon commencement of development. You are required to submit a 'Notice of Commencement' to the Council's CIL Team prior to commencing on site, and failure to provide such information at the due date will incur both surcharges and penalty interest. There are various other charges and surcharges that may apply if you fail to meet other statutory requirements relating to CIL, such requirements will all be set out in the Liability Notice you will receive. You may wish to seek professional planning advice to ensure that you comply fully with the requirements of CIL Regulations.

If you have a specific question or matter you need to discuss with the CIL team, or you fail to receive a 'Liability Notice' from the Council within 1 month of this grant of planning permission, please email us at: [cil@barnet.gov.uk](mailto:cil@barnet.gov.uk).

Relief or Exemption from CIL:

If social housing or charitable relief applies to your development or your development falls within one of the following categories then this may reduce the final amount you are required to pay; such relief must be applied for prior to commencement of development using the 'Claiming Exemption or Relief' form available from the Planning Portal website: [www.planningportal.gov.uk/cil](http://www.planningportal.gov.uk/cil).

You can apply for relief or exemption under the following categories:

1. Charity: If you are a charity, intend to use the development for social housing or feel that there are exception circumstances affecting your development, you may be eligible for a reduction (partial or entire) in this CIL Liability. Please see the documentation published by the Department for Communities and Local Government at [https://www.gov.uk/government/uploads/system/uploads/attachment\\_data/file/6314/19021101.pdf](https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/6314/19021101.pdf)
2. Residential Annexes or Extensions: You can apply for exemption or relief to the collecting authority in accordance with Regulation 42(B) of Community Infrastructure Levy Regulations (2010), as amended before commencement of the chargeable development.
3. Self Build: Application can be made to the collecting authority provided you comply with the regulation as detailed in the [legislation.gov.uk](http://legislation.gov.uk)

Please visit <http://www.planningportal.gov.uk/planning/applications/howtoapply/whattosubmit/cil> for further details on exemption and relief.

- 3 The Air Quality Stage 4 Review and Assessment for the London Borough of Barnet has highlighted that this area currently experiences or is likely to experience exceedances of Government set health-based air quality standards. A list of possible options for mitigating poor air quality is as follows: 1) Use of passive or active air conditioning; 2) Use of acoustic ventilators; 3) Altering lay out so habitable rooms are sited away from source of poor air quality; 4) Non residential usage of lower floors; 5) Altering footprint by siting further away from source of poor air quality.

For developments that require an Air Quality report; the report should have regard to the air quality predictions and monitoring results from the Stage Four of the Authority's Review and Assessment available from the LPA web site and the London Air Quality Network. The report should be written in accordance with the following guidance: 1) Environmental Protection UK Guidance: Development Control: Planning for Air Quality (2010); 2) Environment Act 1995 Air Quality Regulations; 3) Local Air Quality Management Technical Guidance LAQM.TG(09); 4) London Councils Air Quality and Planning Guidance (2007).

Please note that in addition to the above, consultants should refer to the most relevant and up to date guidance and codes of practice if not already listed in the above list.

- 4 The applicant is advised to engage a qualified acoustic consultant to advise on the scheme, including the specifications of any materials, construction, fittings and equipment necessary to achieve satisfactory internal noise levels in this location.

In addition to the noise control measures and details, the scheme needs to clearly set out the target noise levels for the habitable rooms, including for bedrooms at night, and the levels that the sound insulation scheme would achieve.

The Council's Sustainable Design and Construction Supplementary Planning Document requires that dwellings are designed and built to insulate against external noise so that the internal noise level in rooms does not exceed 30dB(A) expressed as an Leq between the hours of 11.00pm and 7.00am, nor 30dB(A) expressed as an Leq between the hours of 7.00am and 11.00pm (Guidelines for Community Noise, WHO). This needs to be considered in the context of room ventilation requirements.

The details of acoustic consultants can be obtained from the following contacts: a) Institute of Acoustics and b) Association of Noise Consultants.

The assessment and report on the noise impacts of a development should use methods of measurement, calculation, prediction and assessment of noise levels and impacts that comply with the following standards, where appropriate:

- 1) BS 7445(2003) Pt 1, BS7445 (1991) Pts 2 & 3 - Description and measurement of environmental noise;
- 2) BS 4142:1997 - Method for rating industrial noise affecting mixed residential and industrial areas;

- 3) BS 8223: 2014 - Guidance on sound insulation and noise reduction for buildings: code of practice;
- 4) Department of Transport: Calculation of road traffic noise (1988);
- 5) Department of Transport: Calculation of railway noise (1995);
- 6) National Planning Policy Framework (2012)/ National Planning Policy Guidance (2014).

Please note that in addition to the above, consultants should refer to the most relevant and up to date guidance and codes of practice if not already listed in the above list.

- 5 In complying with the contaminated land condition parts 1 and 2, reference should be made at all stages to appropriate current guidance and codes of practice. This would include:

- 1) The Environment Agency CLR & SR Guidance documents (including CLR11 'Model Procedures for the Management of Land Contamination');
- 2) National Planning Policy Framework (2012) / National Planning Practice Guidance (2014);
- 3) BS10175:2011 - Investigation of potentially contaminated sites - Code of Practice;
- 4) Guidance for the safe development of housing on land affected by contamination, (2008) by NHBC, the EA and CIEH;
- 5) CIRIA report C665 - Assessing risks posed by hazardous ground gases to buildings;
- 6) CIRIA report C733 - Asbestos in soil and made ground: a guide to understanding and managing risks.

Please note that in addition to the above, consultants should refer to the most relevant and up to date guidance and codes of practice if not already listed in the above list.

- 6 With regard to water supply, this comes within the area covered by the Affinity Water Company. For your information the address to write to is - Affinity Water Company The Hub, Tamblin Way, Hatfield, Herts, AL10 9EZ - Tel - 0845 782 3333.
- 7 Any details submitted in respect of the Demolition and Construction Management Plan above shall control the hours, routes taken, means of access and security procedures for construction traffic to and from the site and the methods statement shall provide for the provision of on-site wheel cleaning facilities during demolition, excavation, site preparation and construction stages of the development, recycling of materials, the provision of on-site car parking facilities for contractors during all stages of development (Excavation, site preparation and construction) and the provision on site of a storage/delivery area for all plant, site huts, site facilities and materials and a community liaison contact and precautions to minimise damage to trees on or adjacent to the site.
- 8 The applicant is advised that Regents Park Rd is a Traffic Sensitive Road; deliveries during the construction period should not take place between 8.00 am-9.30 am and 4.30 pm-6.30 pm Monday to Saturday. Careful consideration must also be given to the optimum route(s) for construction traffic and the Environment and Operations should be consulted in this respect.
- 9 The applicant is also advised that the development is located on a Strategic Road Network (SRN) and is likely to cause disruption. The Traffic Management Act

(2004) requires the Council to notify Transport for London (TfL) for implementation of construction works. The developer is expected to work with the Council to mitigate any adverse impact on public highway and would require TfL's approval before works can commence.

- 10 The applicant must submit an application under Section 184 of the Highways Act (1980) for the proposed new vehicular access and alterations to the existing vehicular access. The proposed access design details, construction and location will be reviewed by the Development Team as part of the application. Any related costs for alterations to the public highway layout that may become necessary, due to the design of the onsite development, including reinstatement of redundant vehicle accesses, will be borne by the applicant. The applicant is advised that Transport for London will be consulted regarding the impact on the bus stop in the vicinity of the proposed vehicle access.

To receive a copy of our Guidelines for Developers and an application form please contact: Traffic & Development Section - Environment, Planning and Regeneration Directorate, London Borough of Barnet, North London Business Park (NLBP) Building 4, Oakleigh Road South, London N11 1NP

- 11 For construction works adjacent to the public highways, the applicant must contact the Council on 0208 359 2000 for any necessary Highways Licenses

- 12 Waste Comments

Surface Water Drainage - With regard to surface water drainage it is the responsibility of a developer to make proper provision for drainage to ground, water courses or a suitable sewer. In respect of surface water it is recommended that the applicant should ensure that storm flows are attenuated or regulated into the receiving public network through on or off site storage. When it is proposed to connect to a combined public sewer, the site drainage should be separate and combined at the final manhole nearest the boundary. Connections are not permitted for the removal of groundwater. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. They can be contacted on 0800 009 3921. Reason - to ensure that the surface water discharge from the site shall not be detrimental to the existing sewerage system.

There are public sewers crossing or close to your development. In order to protect public sewers and to ensure that Thames Water can gain access to those sewers for future repair and maintenance, approval should be sought from Thames Water where the erection of a building or an extension to a building or underpinning work would be over the line of, or would come within 3 metres of, a public sewer. Thames Water will usually refuse such approval in respect of the construction of new buildings, but approval may be granted in some cases for extensions to existing buildings. The applicant is advised to contact Thames Water Developer Services on 0800 009 3921 to discuss the options available at this site.

Thames Water would advise that with regard to sewerage infrastructure capacity, we would not have any objection to the above planning application.

No impact piling shall take place until a piling method statement (detailing the depth and type of piling to be undertaken and the methodology by which such piling will

be carried out, including measures to prevent and minimise the potential for damage to subsurface sewerage infrastructure, and the programme for the works) has been submitted to and approved in writing by the local planning authority in consultation with Thames Water. Any piling must be undertaken in accordance with the terms of the approved piling method statement. Reason: The proposed works will be in close proximity to underground sewerage utility infrastructure. Piling has the potential to impact on local underground sewerage utility infrastructure. The applicant is advised to contact Thames Water Developer Services on 0800 009 3921 to discuss the details of the piling method statement.

Where a developer proposes to discharge groundwater into a public sewer, a groundwater discharge permit will be required. Groundwater discharges typically result from construction site dewatering, deep excavations, basement infiltration, borehole installation, testing and site remediation. Groundwater permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 020 8507 4890 or by emailing [riskmanagement@thameswater.co.uk](mailto:riskmanagement@thameswater.co.uk). Application forms should be completed on line via [www.thameswater.co.uk/wastewaterquality](http://www.thameswater.co.uk/wastewaterquality). Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991.

- 13 The applicant is advised that any development or conversion which necessitates the removal, changing, or creation of an address or addresses must be officially registered by the Council through the formal 'Street Naming and Numbering' process.

The London Borough of Barnet is the Street Naming and Numbering Authority and is the only organisation that can create or change addresses within its boundaries. Applications are the responsibility of the developer or householder who wish to have an address created or amended.

Occupiers of properties which have not been formally registered can face a multitude of issues such as problems with deliveries, rejection of banking / insurance applications, problems accessing key council services and most importantly delays in an emergency situation.

Further details and the application form can be downloaded from: <http://www.barnet.gov.uk/naming-and-numbering-applic-form.pdf> or requested from the Street Naming and Numbering Team via [street.naming@barnet.gov.uk](mailto:street.naming@barnet.gov.uk) or by telephoning 0208 359 7294.

## **Officer's Assessment**

### **1. Site Description**

114 Regents Park Road is a four storey 1960's block of flats located on the junction of Holly Park and Regents Park Road. The ground floor was formally occupied by a petrol filling station but is currently used as a hand car wash. To the rear of the property exist a row of single storey garages with an area of grassed open space. Levels rise from Regents Park Road up Holly Park so that the adjoining property (no.2 Holly Park) is elevated above the rear of the application site. There are 2 mature street trees on Holly Park and a number of established trees located in the rear garden of No.2 Holly Park. The building is currently in use as 6 self contained 2 bedroom residential units.

The site is located in Regents Park Road (A598) which is part of the Strategic Road Network (SRN) at its junction with Holly Park. The site has 3 points of vehicular accesses one via Regents Park Road and 2 via Holly Park.

### **2. Site History**

Reference: C00601L/08

Address: 114 Regents Park Road, London, N3 3JG

Decision: Refused

Decision Date: 10 March 2008

Description: 1no. internally illuminated, single sided, free standing display unit

Reference: C00601H/03

Address: 114 Regents Park Road, London, N3 3JG

Decision: Refused

Decision Date: 2 May 2003

Description: Installation of ATM.

Reference: C00601G/03

Address: 114 Regents Park Road, London, N3 3JG

Decision: Withdrawn

Decision Date: 14 July 2003

Description: Internally illuminated ATM Signage.

### **3. Proposal**

The application proposes to demolish the existing building and erection of a new 4 storey building to create 8no. self-contained flats including lower ground floor level with parking area for 12no. parking spaces and storage; hard/soft landscaping and refuse/recycling facilities.

### **4. Public Consultation**

Consultation letters were sent to 69 neighbouring properties.

5 responses have been received, comprising 5 letters of objection, 0 letters of support and 0 letters of comment.

The objections received can be summarised as follows:

- Loss of amenity - overlooking, loss of privacy, loss of light and outlook.
- Overdevelopment and over dense for the site.



- 1.8m high louvered fence to enclose ground floor patio is disruptive to streetscape.
- There is an increasing attempt to use land in this locality to its maximum.
- Similar to proposal that was refused at neighbouring property 108-112 Regents Park Road.
- Footprint too big and extends too close to neighbouring buildings.
- Other developments referred to in the documentation submitted are less bulky and only comparable in terms of height.
- No attempt by the developers to consult with neighbouring properties.
- No discussion with neighbours as to how issues such as noise will be mitigated.
- Has been no discussion about how this will be mitigated.
- Area is prone to subsidence and removal of oak tree will cause disruption.

## **5. Planning Considerations**

### **5.1 Policy Context**

#### National Planning Policy Framework and National Planning Practice Guidance

The determination of planning applications is made mindful of Central Government advice and the Local Plan for the area. It is recognised that Local Planning Authorities must determine applications in accordance with the statutory Development Plan, unless material considerations indicate otherwise, and that the planning system does not exist to protect the private interests of one person against another.

The National Planning Policy Framework (NPPF) was published on 27 March 2012. This is a key part of the Governments reforms to make the planning system less complex and more accessible, and to promote sustainable growth.

The NPPF states that 'good design is a key aspect of sustainable development, is indivisible from good planning, and should contribute positively to making places better for people'. The NPPF retains a presumption in favour of sustainable development. This applies unless any adverse impacts of a development would 'significantly and demonstrably' outweigh the benefits.

#### The Mayor's London Plan 2015

The London Development Plan is the overall strategic plan for London, and it sets out a fully integrated economic, environmental, transport and social framework for the development of the capital to 2031. It forms part of the development plan for Greater London and is recognised in the NPPF as part of the development plan.

The London Plan provides a unified framework for strategies that are designed to ensure that all Londoners benefit from sustainable improvements to their quality of life.

#### Barnet's Local Plan (2012)

Barnet's Local Plan is made up of a suite of documents including the Core Strategy and Development Management Policies Development Plan Documents. Both were adopted in September 2012.

- Relevant Core Strategy Policies: CS NPPF, CS1, CS5, CS9, CS10, CS15.
- Relevant Development Management Policies: DM01, DM02, DM03, DM04, DM08, DM13, DM14, DM17.

The Council's approach to development as set out in Policy DM01 is to minimise the impact on the local environment and to ensure that occupiers of new developments as well as neighbouring occupiers enjoy a high standard of amenity. Policy DM01 states that all

development should represent high quality design and should be designed to allow for adequate daylight, sunlight, privacy and outlook for adjoining occupiers. Policy DM02 states that where appropriate, development will be expected to demonstrate compliance to minimum amenity standards and make a positive contribution to the Borough. The development standards set out in Policy DM02 are regarded as key for Barnet to deliver the highest standards of urban design.

#### Supplementary Planning Documents

Sustainable Design and Construction SPD (adopted April 2013)

- Provides detailed guidance that supplements policies in the adopted Local Plan, and sets out how sustainable development will be delivered in Barnet.

Residential Design Guidance SPD (adopted April 2013)

### **5.2 Main issues for consideration**

The main issues for consideration in this case are:

- Whether harm would be caused to the character and appearance of the existing building, the street scene and the wider locality;
- Whether harm would be caused to the living conditions of neighbouring residents.

### **5.3 Assessment of proposals**

The principle of the proposed development

The Borough has an attractive and high quality environment that the Council wishes to protect and enhance. It is therefore considered necessary to carefully assess both the design and form of new development to ensure that it is compatible with the established character of an area that is defined by the type and size of dwellings, the layout, intensity, and relationship with one another and their surroundings. Proposals involving the redevelopment of sites in residential localities are required to reflect the particular character of the street in which the site is located and the scale and proportion of the houses.

The Council recognises that flat developments can make a valuable contribution to housing provision, in particular smaller units and that they can make more efficient use of urban land, however they normally involve an intensification of use creating more activity and can adversely affect the appearance of a street through, for example, the provision of car parking and refuse facilities, that can have an unacceptable impact on the established character of an area.

Suitable locations for flatted developments include areas in or adjacent to town centres or easily accessible by public transport, along major roads and areas characterised by non-family units such as flats, bed sits or HMO's.

Core Strategy Policy CS4: Providing Quality Homes and Housing Choice in Barnet, the aim is to maximise housing choice providing a range of sizes and types of accommodation.

The proposal will provide a mix of dwelling types including 6 x 2 bedroom dwellings and 2 x 3 bedroom units.

The redevelopment of the site for residential accommodation is considered to be acceptable.

The impact on the character and appearance of the application site and surrounding area

The 2012 National Planning Policy Framework states that 'the Government attaches great importance to the design of the built environment. Good design is a key aspect of sustainable development, is indivisible from good planning, and should contribute positively to making places better for people'.

In addition to the NPPF, Policy CS5 of the Core Strategy states that the Council 'will ensure that development in Barnet respects local context and distinctive local character creating places and buildings of high quality design'. In addition to this, Policy DM01 of the Council's Development Management Policies 2012 states that 'development proposals should preserve or enhance local character and respect the appearance, scale, mass, height and pattern of surrounding buildings, spaces and streets' development (should) demonstrate a good understanding of the local characteristics of an area. Proposals which are out of keeping with the character of an area will be refused'.

The existing building is not of architectural merit to warrant its retention. The demolition of the building is accepted. The new building will project forward of the existing building line of the property and will align with the front building line of the neighbouring property 108-112 Regents Park Road and the remainder of the parade. There are no side windows in the flank wall of neighbouring property that will be unduly harmed by this increased forward projection. The increased forward projection is considered acceptable as this would bring the building line in line with the rest of the established building lines in the street.

The overall height of the building will be lower than the existing building, although the overall size and scale of the building will be increased the new proposal uses the change in levels from the front to back of the site to provide an additional basement level for car parking, the only visual manifestation of this from the street level is the access ramp leading down.

The overall design of the building with flat roof is considered to be acceptable and the introduction of balconies to the front and rear elevation of the development is considered to be in keeping with the surrounding area where a number of flatted developments have large balcony features.

The impact on the amenity of future and neighbouring residents

The proposed works would result in the creation of 8 self contained units. Policy DM01 of the Development Management Policies 2012 states that all development should represent high quality design and should be designed to allow for adequate daylight, sunlight, privacy and outlook for adjoining occupiers.

Section 8.4 of Barnet's Local Plan SPD: residential design guidance states: "in designing high quality amenity space, consideration should be given to privacy, outlook, sunlight, trees and planting, materials (including paving), lighting and boundary treatment. All dwellings should have access to outdoor amenity space that is not overlooked from the public realm and provides reasonable level of privacy". In addition to this, section 2.4 of the SPD for sustainable design and construction states that "the impact of development on the availability of daylight / sunlight and privacy to the occupants of existing buildings and the occupants of new development is strongly influenced by design and contributes significantly to the quality of life. The amount of daylight available in buildings enhances people's quality of life and reduces energy use. The Mayor's Housing SPG standard 5.5.2

recommends that development should preferably have direct sunlight in living areas and kitchen dining spaces and all homes should provide for direct sunlight to enter at least one habitable room for part of the day. Overheating should be considered when designing for sunlight".

The proposed flats are in excess of the minimum space standards as set out in the London Plan and would provide sufficient outlook and access to light for habitable rooms. The flats on the upper floors are all dual aspect and each room has more than 20% glazing for the size of the room. Basement/lower ground floor units will be served by a large lightwell. Generally officers do not consider that lightwells could provide adequate levels of light and outlook however, in this instance given the site specific circumstances of this development and its design and the size of the proposed void lightwell measuring approximately 9m x 6.5m it is considered that this would sufficiently provide the lower ground floor unit (flat 2) with adequate levels of light and amenity. It should be noted that each habitable room within flat 2 which is within the lower ground floor level will have no less than 40% glazing for the floor area of each room. It is the specifics of this design which makes the proposal acceptable in this instance.

Amenity Space provided complies with the councils standards. Outdoor amenity space for the upper floor units will be provided through their private balconies. The ground floor garden area has been designed in such a way to ensure that adequate privacy is provided for the future occupiers of the flats. Dedicated garden space will be provided for the ground floor units to ensure there is no overlooking from the garden space into the windows of these flats from other occupiers of the development. Flat 2 will have access to private amenity space by way of the void lightwell. An additional area of communal amenity space is also provided for the use of future occupiers of the proposed units.

#### Amenity of neighbouring occupiers

The proposal has been amended since its initial submission to mitigate against harm to the neighbouring property 108-112 Regents Park Road. The building will project 4m beyond the rear building line of the neighbouring property, currently it project 4.5m beyond this line. The proposal is then stepped in from the boundary by 3.5m and projects an additional 4.9m. It is considered that given the extensions at the neighbouring property which benefits from a single storey rear extension and first floor rear extension and given the established building line of the existing property at the application site, and the reduction in height of the proposed scheme in comparison to the existing building on site and the amendments to the scheme it is considered that the proposal is acceptable.

In regards to the neighbouring property to 2 Holly Park which is sited to the rear of the application site a distance of 14.6m would be maintained between the flank wall of the neighbouring property and the first to third floor levels of the proposal. It is considered that there is sufficient distance between the neighbouring property and no.2 Holly Park to ensure that the proposal will not appear oppressive or unduly bulky. It should be noted that there are no windows in the flank wall of no 2 Holly Park therefore there will be no loss of outlook.

The distance of the proposed rear facing balconies facing directly on to the flank wall of no 2 Holly Park are in excess of 10.5m from the neighbouring boundary and as such comply with Barnet's guidelines which recommend a minimum distance of 10.5m from windows to garden areas. This guide is also considered relevant when considering overlooking distances between balconies and neighbouring gardens. Privacy screens will also be provided around the balconies to further prevent any perception of overlooking.

## Contaminated land, noise and air pollution

The environmental health team have reviewed the application and consider the site acceptable for residential use. Given the sites historic use as a petrol station a condition for a contaminated land investigation is required.

With suitable conditions, for acoustic details the proposal is not considered to result in harm to the future occupiers and the existing neighbouring residential occupiers by way of noise and disturbance.

The area is not in an air of high levels of air pollution which would suggest that balconies are an acceptable feature.

## Traffic and highways

The proposal is for demolition of existing building, previously use of a petrol station at ground floor level (more recently operating as a car wash) and 6 x 2 and 2 x 3 bedrooms flats comprising a total of 8 units.

The site is located in Regents park road in close proximity to bus routes and has a public transport accessibility level (PTAL) score of 3 which represents a medium accessibility level. The site is not within a controlled parking zone (CPZ)

A total of 12 off street parking spaces will be provided at the underground car parking area accessed via a ramp from Regents Park Road.

The parking provision is in accordance with parking standards as set out in the Barnet Local Plan Development Management Policies approve in September 2012.

It should noted that the maximum width of the dropped kerb allowed is 4.8 metres. The proposed vehicle access will require an application under Section 184 of the Highways Act which will be subject to detailed assessment, following this assessment the details including width of proposed vehicle access will be agreed. The costs of all works on the public highways associated with the proposed vehicle access including reinstatement of the existing redundant crossovers will be borne by the applicant.

The proposed access to the car parking area due to its width does not allow for 2 way movement, therefore it will be required for a warning system to be provided to warn motorists that a vehicle is entering or leaving the site, giving preference to vehicles entering the site as well as a passing point within the site at both ends of the ramp. It is suggested that a condition is attached to the planning permission to provide details of the proposed access including ramp layout and gradient and passing points for approval by the Planning Authority. The submitted Transport assessment dated February 2015 prepared by Paul Mews Associated provides adequate management control proposals at the ramp giving preference to vehicles entering the site, as well as suitable passing points at both ends of the ramp.

The Transport Assessment also includes swept path details showing that vehicles can manoeuvre into and out of the site and underground parking spaces.

Refuse collection points are provided at a suitable location within 10 metres of the public highways, therefore the proposed refuse collection details are acceptable on highways grounds.

It is anticipated that the proposed residential use of the site, which will increase the number of dwellings from 6 to 8 and remove the ground floor previous commercial uses, will generate a much lower number of vehicle trips to the site compared to its previous use as a petrol station and car wash. Therefore no additional traffic impact on the public highways is expected.

#### 5.4 Response to Public Consultation

All planning related matters are considered to be covered in the above appraisal.

#### 6. Equality and Diversity Issues

The proposal does not conflict with either Barnet Council's Equalities Policy or the commitments set in the Equality Scheme and supports the Council in meeting its statutory equality responsibilities.

#### 7. Conclusion

The proposal is considered to accord with the requirements of the Development Plan and is therefore recommended for approval.

